

1.1.9 Disponibilidad unidades térmicas, Marzo 2011. Cuadro Tabulado.

Unidad Generadora	Operación		Fuera de Servicio	Disponibilidad		Indisponible
	(Horas)	%	(Horas)	(Horas)	%	%
Itabo II	744.00	100.00	0.00	744.00	100.00	0.00
Los Mina V	744.00	100.00	0.00	744.00	100.00	0.00
Los Mina VI	744.00	100.00	0.00	744.00	100.00	0.00
Metaldom	744.00	100.00	0.00	744.00	100.00	0.00
Mitsubishi	744.00	100.00	0.00	744.00	100.00	0.00
Palamara	744.00	100.00	0.00	744.00	100.00	0.00
Barahona Carbon	741.95	99.72	2.05	744.00	100.00	0.00
CEPP II	729.58	98.06	14.42	744.00	100.00	0.00
La Vega	640.77	86.13	103.23	744.00	100.00	0.00
Rio San Juan	403.32	54.21	340.68	744.00	100.00	0.00
Haina I	0.00	0.00	744.00	744.00	100.00	0.00
Puerto Plata II	0.00	0.00	744.00	744.00	100.00	0.00
CEPP I	686.62	92.29	57.38	743.68	99.96	0.04
Monte Rio	705.35	94.81	38.65	742.95	99.86	0.14
San Felipe	578.50	77.76	165.50	740.53	99.53	0.47
Pimentel III	739.43	99.39	4.57	739.43	99.39	0.61
Pimentel II	554.25	74.50	189.75	713.32	95.88	4.12
Sultana del Este	712.37	95.75	31.63	712.37	95.75	4.25
Estrella del Mar	709.72	95.39	34.28	709.72	95.39	4.61
Haina (TG)	137.43	18.47	606.57	708.67	95.25	4.75
Pimentel I	559.03	75.14	184.97	702.27	94.39	5.61
Itabo I	689.13	92.63	54.87	689.13	92.63	7.38
Estrella del Norte	641.65	86.24	102.35	641.65	86.24	13.76
Macoris II (CC)	359.00	48.25	385.00	547.05	73.53	26.47
Macoris I (CC)	72.55	9.75	671.45	536.50	72.11	27.89
Macoris III (CC)	386.33	51.93	357.67	531.67	71.46	28.54
AES Andres	309.00	41.53	435.00	309.00	41.53	58.47
Haina IV	5.60	0.75	738.40	64.30	8.64	91.36
Haina II	0.00	0.00	744.00	0.00	0.00	100.00
Puerto Plata I	0.00	0.00	744.00	0.00	0.00	100.00

Fuente: Informes de Calidad de la Empresa de Transmisión Dominicana.

Este cuadro tabulado, muestra la disponibilidad de cada uno de los generadores conectados al SENI en marzo del año 2011.